


# National Guard Products, Inc.

1-800-  
647-7874



## 9800 Self Adhesive Fire Seal

UL Tested and Classified for Fire Doors



### Installation Instructions

1. The surface temperature of the frame must be above 50° F. for the adhesive to bond.
2. Clean frame with clean wipe provided to remove dust, oil, grease and dirt. Wax coated or high gloss painted surfaces may require roughening of the surface with a scotch brite pad or sandpaper so adhesive will properly bond.
3. Measure and pre-cut pieces to fit where seal is to mount.
4. Remove protective backing 1 to 2 feet at a time.
5. Position where illustrated for application required.
6. Adhere by pressing firmly (approx. 15 lbs. pressure required) straight down along entire length of gasketing. Do not remove and relocate.
7. Make sure the seal does not impede proper closing and latching of the door.



Made in USA



UL 10C Positive Pressure Tested Gasketing Material for steel type fire doors rated up to 3 hours and wood type fire doors up to 1 1/2 hours.



**NGP-EDGE®** Sealing System (Category G) intended for perimeter application to Classified category B wood type fire doors rated up to 90 minute, single swing up to 4'0"x9'0" and standard pairs up to 8'0"x9'0".

**NGP-EDGE®** Sealing System (Category G) for meeting edge (astragal) application to Classified category B wood type fire doors rated up to 20 minutes with single strip installed or up to 60 minute when two strips installed on up to 8'0"x9'0" pairs.



UL10B Gasketing Material for Fire Doors. Intended for Application to Classified steel type fire doors rated up to 3 hours and wood type fire doors up to 1 1/2 hours.

### STORAGE AND SHELF LIFE

The adhesive on this seal has a shelf life of one year stored at 75° F and 50% relative humidity or less