

National Guard Products Inc.

1-800-
647-7874



L-FRA 100-SP (Low Profile) for variable door and/or glass thickness

INSTALLATION INSTRUCTIONS

1. Cut out door in accordance with door manufacturers listing procedure. Steel fire-rated doors do NOT require an opening reinforcing channel or reinforcing clips.
2. Install glass & glazing material (sold separately), into lite kit.
3. Position outer frame in door cut out.
4. Position inner frame and insert and start all screws before fully tightening.
5. Tighten screws using a criss cross pattern. Use caution when using power screw driving equipment to avoid stripping the material.

For Fire Rated Doors, using 1/4" thick fire rated wire glass

20 & 45 minutes = 1,296 sq. inches max visible glass, 54" max width, 54" max height.

60 & 90 minute = 100 sq. inches max visible glass, 10" max width, 33" max height.

Sizes exceeding those shown above may be achieved using FireLite NT, Fire-Lite Plus, Pilkington Pyrostop or Fireglass 20.

Maximum size is determined by the glass listing (in doors) and door manufacturers listing.

UL10C Positive Pressure rated fire doors using Fire-Lite NT, Fire-Lite Plus, Pilkington Pyrostop or Fireglass 20 require closed cell polyvinyl (PVC) foam glazing tape like NGP GT-116 or GT118.

FIELD PAINTING: for best results scuff finish with a Scotch-brite pad or sand paper before painting.
4/07



LISTED
Fire Door Glass Lite
76SF

