



For the complete list of GapGuard Fire Door Accessories, the most up-to-date product information and installation instructions, scan the QR code or visit [ngp.com](http://ngp.com).



# GAPGUARD

Fire Door Accessories

## SOLVING FIRE DOOR NON-COMPLIANCES

### EXCESSIVE GAP

#### DOOR JAMB (LATCH & HINGE SIDE)

##### OPTION 1: GAP90


- If excessive gap is  $\frac{3}{8}$ " or less
- If soffit depth **greater than  $1\frac{3}{8}$ "**
- Where used: applied to frame

**NOTE:** all three components must be used at location of excessive gap

##### OPTION 2: GAP90N

- If excessive gap is  $\frac{3}{8}$ " or less
- If soffit depth is **equal to or less than  $1\frac{3}{8}$ "**
- Where used: applied to frame

**NOTE:** All three components must be used at location of excessive gap.



### EXCESSIVE GAP

#### DOOR BOTTOM

##### OPTION 1: 9590 DOOR BOTTOM GAP

- If excessive gap is  $1\frac{1}{2}$ " or less
- Where used: applied to the bottom of the door, attached to both faces of the door

**NOTE:** No moving parts. More visible than 9595.

##### OPTION 2: 9595 DOOR BOTTOM GAP

- If excessive gap is  $1\frac{3}{8}$ " or less
- Where used: applied to the bottom of the door, attached to only one face of the door, or underneath the bottom rail

**NOTE:** Assembly moves  $\frac{3}{8}$ " to accommodate uneven floors. Less visible than 9590.



### EXCESSIVE GAP

#### DOOR TOP

##### OPTION 1: GAP90

- If excessive gap is  $\frac{3}{8}$ " or less
- If soffit depth **greater than  $1\frac{3}{8}$ "**
- Where used: applied to frame

**NOTE:** all three components must be used at location of excessive gap


##### OPTION 2: GAP90N

- If excessive gap is  $\frac{3}{8}$ " or less
- If soffit depth is **equal to or less than  $1\frac{3}{8}$ "**
- Where used: applied to frame

**NOTE:** All three components must be used at location of excessive gap.

##### OPTION 3: 9990 DOOR TOP GAP

- If excessive gap is  $\frac{1}{2}$ " or less
- If parallel arm closer is used
- Where used: applied to the top of door, attached to both faces of the door



### EXCESSIVE GAP


#### PAIRS & SINGLES

Meeting Edge,  
Perimeter of Door,  
and HM Door Frames

##### OPTION 1: GAP90-ME

- If excessive gap is  $\frac{3}{8}$ " or less
- Where used: applied to the meeting edge of one of the doors, or perimeter of door or HM frame
- Key detail: refer to installation instructions for wood door vs metal door

**NOTE:** Formed metal edge can be flattened as needed to maintain consistent reveal.



# GAPGUARD

SOLVING FIRE DOOR NON-COMPLIANCES (continued)

## HOLES IN DOOR

### FACE OF DOOR

#### OPTION 1: FIRE CAULK

- If hole is ½" or less
- Where used: on the face of the door to fill holes (typically left from hardware fasteners)

**NOTE:** Mostly for use on wood doors, but UL Listed for metal doors and frames as well.


#### OPTION 2: HP90-0.5, HP90-1.0, HP90-1.5, HP90-2.0 FILLER PLUGS

- Where used: on the face of the door to fill holes (typically left from hardware fasteners)

**NOTE:** Must be used with Fire Caulk. Mostly for use on wood doors, but UL Listed for metal doors and frames as well.

Sold in Cases of 10 ea. 10.3 oz. Cartridges or Cases of 6 ea. 3.0 oz. Tubes

APPLICABLE  
IN VARIOUS  
LOCATION(S)




## HARDWARE PREP FILLER

### HARDWARE PREP LOCATION

#### OPTION 1: HP90-CYL

- If cylindrical hardware prep needs filled
- Where used: at location of existing cylindrical lockset hardware prep



APPLICABLE IN VARIOUS  
LOCATION(S)

**NOTE:** Kit includes fire caulk, filler panel, edge filler plates for door and frame, and hardware. Mostly for use on wood doors, but UL Listed for metal doors as well.

#### OPTION 2: HP90-MORT

- If mortise lockset hardware prep needs filled
- Where used: at location of existing mortise lockset hardware prep

**NOTE:** Kit includes fire caulk, filler panel, edge filler plates for door and frame, and hardware. Mostly for use on wood doors, but UL listed for metal doors as well.

#### OPTION 3: HP90-FB

- If flush bolt hardware prep needs filled
- Where used: at location of existing flush bolt hardware prep

**NOTE:** Kit includes fire caulk, filler panel, edge filler plates for door and frame, and hardware. Mostly for use on wood doors, but UL Listed for metal doors as well.

NGP-GAP-SFD-0425-A



MEMPHIS | CARSON CITY

### NATIONAL GUARD PRODUCTS, INC.

**MEMPHIS**  
4985 East Raines Road  
Memphis, TN 38118

**CARSON CITY**  
3689 Arrowhead Drive  
Carson City, NV 89706

**Fax:** (800) 255-7874

**Email:** info@ngp.com

**Quotes:** quotes@ngp.com

**Orders:** orders@ngp.com

**ngp.com**  
1-800-NGP-RUSH