

CERTIFICATE OF COMPLIANCE

Certificate Number 20181220-R25568
Report Reference R25568-20141223
Issue Date 2018-DECEMBER-20

Issued to: NATIONAL GUARD PRODUCTS INC
4985 E RAINES RD
MEMPHIS TN 38118-7024

**This certificate confirms that
representative samples of**

MISCELLANEOUS FIRE DOOR ACCESSORIES,
Complementary Product Category MISCELLANEOUS FIRE
DOOR ACCESSORIES, POSITIVE-PRESSURE TESTED
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/UL 10C- Positive Pressure of Fire Tests of Door
Assemblies.
ANSI/UL 10B - Fire Tests of Door Assemblies.
CAN/ULC-S104 - Standard Method for Fire Tests of Door
Assemblies.


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20181220-R25568
Report Reference R25568-20141223
Issue Date 2018-DECEMBER-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

NGP-Edge® Sealing System, Model 9200, self-adhesive intumescent seal and Model 9275/9225, Strike shims rated up to and including 20 minutes. May include additional suffix letters: DKB

NGP-Edge® Sealing System, GAP90 consisting of Models 9400, 9945, 5075, and Model 9275/9225, Strike shims rated up to and including 1-1/2 hour. May include use of Model SS306 in 3/4 hour applications. May include additional suffix letters: B, CL, DKB.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

