

CERTIFICATE OF COMPLIANCE

Certificate Number 20190308-R25568
Report Reference R25568
Issue Date 2019-March-08

Issued to: NATIONAL GUARD PRODUCTS INC.
4985 E Ranines Rd.
Memphis, TN 38118

This is to certify that representative samples of Miscellaneous Fire Door Accessories
Miscellaneous Fire Door Accessories Certified for Canada
Positive Pressure Fire Tests of Door Assemblies

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10B, "Fire Tests of Door Assemblies,"
ANSI/UL 10C, "Positive Pressure Fire Tests of Door Assemblies."
CAN/ULC-S104, "Standard Method for Fire Tests of Door Assemblies."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

See addendum page 2.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190308-R25568
Report Reference R25568
Issue Date 2019-March-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

NGP-Edge® Sealing System, GAP90 - consisting of Models 9400, 9945, 5075 and 9275/9225, gap solution for excessive door and frame clearances when installed per the manufacturer's instructions, intended for use with UL Classified steel composite, hollow metal doors, wood and plastic-covered composite core doors and UL Listed fire door frames up to 1-1/2 hour and, wood core doors and UL Listed fire door frames rated up to 20 minutes. Product may include additional suffix letters: B, CL, DKB. Models SS306 and SS304 may be used in doors rated up to and including 3/4 hour.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

