

CERTIFICATE OF COMPLIANCE

Certificate Number 20191009-R25568
Report Reference R25568-20141223
Issue Date 2019-OCTOBER-09

Issued to: NATIONAL GUARD PRODUCTS INC
4985 E RAINES RD
MEMPHIS TN 38118-7024

**This certificate confirms that
representative samples of**

MISCELLANEOUS FIRE DOOR ACCESSORIES;
MISCELLANEOUS FIRE DOOR ACCESSORIES,
POSITIVE-PRESSURE TESTED

See Addendum for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/UL 10C, Positive Pressure of Fire Tests of Door
Assemblies
ANSI/UL 10B, Fire Tests of Door Assemblies
CAN/ULC-S104, Standard Method for Fire Tests of Door
Assemblies

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191009-R25568
Report Reference R25568-20141223
Issue Date 2019-OCTOBER-09


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

NGP-Edge® Sealing System, Model 9200, self-adhesive intumescent seal and Model 9275/9225, Strike shims rated up to and including 20 minutes. May include additional suffix letters: DKB

Model 9990 Intumescent Door Cap System for use with 1-1/2 hr swinging type fire doors.

NGP-Edge® Sealing System, GAP90 consisting of Models 9400, 9945, 5075, and Model 9275/9225, Strike shims rated up to and including 1-1/2 hour. May include use of Model SS306 in 3/4 hour applications. May include additional suffix letters: B, CL, DKB.

NGP-Edge® Sealing System, GAP90 consisting of Models 9400, 9945, and 5075, for use with RIM Type Fire-exit hardware, rated up to and including 1-1/2 hour.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

