

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140620-R10042 |  
**Report Reference** R10042  
**Issue Date** 2014-June- 20 |

**Issued to:** National Guard Products Inc. |  
4985 E Raines Rd  
Memphis, TN 38118 |


**This is to certify that representative samples of** Gasketing Materials for Fire Doors |  
See pages 2-5 |

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** ANSI/UL 10B, "Fire Tests of Door Assemblies."  
CAN/ULC-S104, "Standard Method for Fire Tests of Door Assemblies." |

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle: with the word "CLASSIFIED"  (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE


Certificate Number 20140620-R10042  
Report Reference R10042  
Issue Date 2014-June- 20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Thresholds, Single piece and assemblies with and without stops, covers made of metal, with and without flexible inserts. Model Nos. BAR1, BAR1BR, 2, BAR2, BAR2SS, BAR2BR, BAR3, BAR3BR, 4, BAR4, BAR4BR, BAR5, BAR5BR, BAR6SS, RCE-9, RCE-15, RCE-21, RCE-30, RO50, R50, 57, 58, 58BR, RO75, R75, 80A, 80B, 82A, 83, 83BR, RO100, R100, 111, 123, RO125, R125, RO150, R150, RO175, R175, RO200, R200, 211, 215, 215BR, RO225, R225, RO250, R250, 315, 315BR, 321, 322, 322BR, 323, 324, 325, 325BR, 325HD, 327, 327BR, 350, 350BR, 355, 404, 404BR, 404-75, 407, 408, 410, 411, 411BR, 412, 412SS, 413, 413BR, 413SS, 414, 415, 415BR, 416, 417, 417BR, 418BR, 424, 424BR, 424E, 425, 425BR, 425E, 425HD, 426, 426BR, 426E, 427, 427BR, 427E, 428BR, 428E, 429BR, 429E, 430BR, 430E, 432, 432BR, 437, 440, 442BR, 442-5, 455, 457, 458, 473BR, 481BR, 483BR, 484BR, 512, 512SS, 513, 513BR, 513HD, 513SS, 525, 612SS, 613, 613SS, 613BR, 653, 654, 655, 656, 657, 658, 659, 700E, 712SS, 713, 713SS, 713BR, 803, 804, 812SS, 813, 813SS, 813BR, 814, 814SS, 818, 818SS, 818BR, 828, 838, 882, 883SS, 884SS, 884, 884-6, 884-7, 884-8, 885, 885-6, 885-7, 890, 891, 893, 894, 895BR, 896, 896BR, 896HD, 896SS, 897, 897SS, 898, 912SS, 913, 913SS, 950, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 1012SS, 1013, 1013SS, 4413, 4424, 4425, 4513, 4884, 4891, 8132, 8133, 8134, 8135, 8136, 8136BR, 8137, 8138, 8139, 8139BR, 8140, 8140BR, 8141, 8141BR, 8142, 8142BR, 8143, 8143BR, 8144, 8144BR, 8145, 8145BR, 8146, 8146BR, 8147, 8148, 8149, 8150, 8152, 8163, 8164, 8167, 8168N, 8170, 8475 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. Products may include additional suffix letters: A, B, B/S, Bead Blasted, DKB, FC, POL, SIA. Item numbers may also include letters: V, VV, S, N, and P when insert material is provided.

Threshold Extensions, Model No. 400, Category J threshold extensions are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs.

Automatic Door Bottom, Model Nos. 220N, 220S, 220WH, 221NSS, 221SSS, 221WHSS, 222N, 222S, 222WH, 223N, 223S, 225N, 225S, 225WH, 229NSS, 229SSS, 310N, 310S, 310WH, 335N, 335S, 420N, 421N, 423N, 520N, 680, 683, 780S, 780V, 4440S, 4440WS, 4441S, 4441WH, 4440WH, 4447S, 4447WH, 4448S, 4448WH are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. Products may include additional suffix letters: A, B, DKB.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140620-R10042 |  
**Report Reference** R10042  
**Issue Date** 2014-June- 20 |

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Automatic Door Bottom, Model Nos. 422N, 522N, 682 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 3/4 hrs. Products may include additional suffix letters: A, B, DKB.

Automatic Door Bottom, Model Nos. 320N, 320S, 320V are intended for application to/with Classified Hollow Metal and Steel Covered Composite Type Fire Doors rated up to and including 3 hrs.

Door Bottom Seal, Model Nos. 5V, 6V, 12T, 12V, 13T, 13V, 15N, 18V, 19V, 26N, 35ET, 35EV, 35V, 36ET, 36EV, 36V, 95WH, 95WHDKB, 99NWH, 99WH, 99N, 99T, 99V, 99TWH, 99VWH, 112N, 113N, 118N, 119 N, 312V, 313V, 318V, 319ET, 319EV, 319V, 344, 344NF, 618 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. Products may include additional suffix letters: A, B, DKB, DM.

Door Sweep, Model Nos. 96V, 97V, 98V, 100V, 101V, 102V, 197N, 198N, 198U, 199N, 200N, 200NBR, 200NSS, 200S, 200SBR, 200SSS, 200U, 200UBR, 200USS, 201N, 202N, 600, 601, 672, 673, 674, 675, 678, 679, A605, B606, C607, D608, G610, H612, C627, OV633, OV634, 1015V, 2104R, 9600, 9605, 9675 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and Wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. Products may include additional suffix letters: A, B, DKB, DM.

Perimeter Seal, Model Nos. 103N, 104N, 106N, 106S, 107N, 107S, 108N, 110N, 110S, 120N, 120NBR, 120NSS, 120S, 120SBR, 120SSS, 122N, 122NSS, 127N, 127NSS, 127S, 127SSS, 129N, 129NBR, 129NSS, 129U, 129UBR, 129USS, 130N, 130NBR, 130NSS, 130S, 130SBR, 130SSS, 131N, 132N, 133N, 134N, 134S, 135N, 137N, 137S, 141N, 141P, 141S, 150U, 152S, 152V, 155S, 155V, 156S, 156V, 157M, 159M, 160S, 160U, 160V, 161N, 161P, 161S, 161U, 161V, 162S, 164V, 165N, 165S, 170N, 170P, 170S, 170V, 172N, 172S, 172V, 184Q, 185P, 190V, 303N, 304N, 600, 601, A602, 603, 672, 675, A605, B606, C607, D608, G610, H612, A617, C619, A625, F625, A626, OV633, OV634, D648, 670, 700EN, 700ES, 700EU, 700N, 700S, 700U, 701EP, 701P, 703EV, 703V, 704EV, 704V, 705EV, 705V, 706, 706E, 1038N, 3038N, 5100N, 5100S, 9000, 9001, 9002, 9600, 9605, 9675, 9750, 9700, 9700E, 9706E are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and Wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. Products may include additional suffix letters: A, B, DKB.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140620-R10042 |  
**Report Reference** R10042  
**Issue Date** 2014-June- 20 |

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Perimeter Seal, Model Nos. D620, G622, H623, I-624 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1 hr. Products may include additional suffix letters: A, B, DKB.

Perimeter seal , Model Nos. 9550, 9500, for use with wood and plastic covered composite doors rated up to 1-1/2 hr, wood core doors rated 20 minute fire tested without hose stream, Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs, wood and plastic covered composite doors rated up to 1-1/2 hrs.


Perimeter seal , Model Nos. 9800, 9850, 9750, for use with wood and plastic covered composite doors rated up to 1-1/2 hr, wood core doors rated 20 minute fire tested without hose stream, Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs.

Perimeter seal , Model No. 9450, for use with wood and plastic covered composite doors rated up to 1-1/2 hr, wood core doors rated 20 minute fire tested without hose stream, Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs.

Brush Seal, Model Nos. 600, 601, 602, 603, A605, A617, B606, C607, D608, G610, G611, H612, H614, I-615, I-616, C619, D620, G622, H623, I-624, A625, A626, C627 are intended for application to/with listed steel fire door frames and/or Classified Steel Covered Composite, Hollow Metal Sliding, Rolling Steel and Passenger Elevator Type Fire Doors rated up to and including 4 hrs. Products may include additional suffix letters: A, B, DKB.

Self-Adhesive perimeter seal, Model Nos. PF180, PF183 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1 hr.

Self-Adhesive perimeter seal, Model Nos. 2525, 5020, 5021, 5025, 5040, 5050, 5060, 5070, 9450, 9550, 9850 are intended for application to/with Classified hollow metal and steel covered composite type fire Doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. Products may include additional suffix letters: B, C, CL, W, T.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140620-R10042 |  
**Report Reference** R10042  
**Issue Date** 2014-June- 20 |


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Self-Adhesive perimeter seal, Model No. 5075 for use with Classified wood and plastic covered composite and wood core doors rated up to 1-1/2 hr., and Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs.

Astragal Seal, Model Nos. 115N, 125N, 125NSS, 139SP, 1392SP, 140S, 158, 540, 541, 542, 543, 545, 550, 551, 552, 553, 555, 560, 561, 562, 563, 565, 570, 572, 574, 575, 600, A605, B606, 672, 675, 5070, 9115, 9125, 9600, 9605, 9675 are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hr. Products may include additional suffix letters: A, B, BR, DKB, N, S, SS, V.

Astragal Seal, Model No. 140P is intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 20 mins. Products may include additional suffix letters: A, B, DKB.

The application of any color powder coat paint 1-1/2 mil to 3 mil thick on any product listed above is permissible and does not affect rating or classification.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

