


# NCP T038

## Adjustable Perimeter Seal



# SEAL



**BHMA**  
CERTIFIED



POSITIVE PRESSURE TESTED GASKETING MATERIALS FOR FIRE DOORS FOR APPLICATION TO HOLLOW-METAL-TYPE FIRE DOORS RATED UP TO 3 HOURS AND WOOD-TYPE FIRE DOORS RATED UP TO 1½ HOURS. CATEGORY H.

SMOKE AND DRAFT CONTROL GASKETING (CATEGORY H) TESTED TO UL 1784; MEETS REQUIREMENTS OF NFPA 105, IBC FOR USE ON "S" LABEL DOORS.

- ▶ Aluminum Alloy 6063, T5 Temper
- ▶ #6 X ¾" or #6 X 1 ½" Stainless Steel SMS Furnished
- ▶ Flame/Moisture Resistant

**ngp.com**

**1-800-NCP-RUSH**

See [ngp.com](http://ngp.com) for All Applicable Certifications for this Product.

---

# INSTALLATION INSTRUCTIONS

---



## **WARNING:**

Neoprene products can expose you to chemicals including chloroprene, which is known to the State of California to cause cancer and/or developmental and reproductive harm. For more information, go to [P65Warnings.ca.gov](http://P65Warnings.ca.gov).

## **1038**

1. Set adjustment to mid range, so it can be adjusted equally in or out.
2. Cut to length.
3. With door closed, position seal, mark screw holes.
4. Drill pilot holes for screws using a #36 drill bit.
5. Install with screws provided, working from one end to the other. **DO NOT OVERTIGHTEN, OR ADJUSTMENT ABILITY MAY BE EFFECTED.**
6. Adjust seal so gasket is slightly compressed against door, but does not impede proper closing or latching.



**[ngp.com](http://ngp.com)**

**1-800-NGP-RUSH**

FAX: (800) 255-7874

QUOTES: [quotes@ngp.com](mailto:quotes@ngp.com)

ORDERS: [orders@ngp.com](mailto:orders@ngp.com)

### **MEMPHIS**

4985 East Raines Road  
Memphis, TN 38118

### **CARSON CITY**

3689 Arrowhead Drive  
Carson City, NV 89706