




139SP

Solid Metal
Astragal



See ngp.com for
All Applicable
Certifications for
this Product.



POSITIVE PRESSURE
TESTED GASKETING
MATERIALS FOR
FIRE DOORS FOR
APPLICATION TO
HOLLOW-METAL-
TYPE FIRE DOORS
RATED UP TO 3
HOURS AND WOOD-
TYPE FIRE DOORS
RATED UP TO
1½ HOURS.
CATEGORY J



ngp.com

1-800-NGP-RUSH

FAX:

(800) 255-7874

QUOTES:

quotes@ngp.com

ORDERS:

orders@ngp.com



INSTALLATION INSTRUCTIONS

139SP



1. Cut astragal to fit.
2. Position on door face with astragal overlapping gap and other door a minimum of $\frac{3}{4}$ " (required by U.L. on fire-rated doors).
3. Mark screw holes.
4. Drill pilot holes for screws using a $\frac{1}{16}$ " drill bit.
5. Install with #12 x $1\frac{1}{4}$ " SMS.
6. Adjust position so astragal does not impede proper closing and latching of door.

ngp.com

1-800-NGP-RUSH

FAX: (800) 255-7874

QUOTES: quotes@ngp.com

ORDERS: orders@ngp.com

NGP MEMPHIS

4985 East Raines Road
Memphis, TN 38118

CARSON CITY

3689 Arrowhead Drive
Carson City, NV 89706